


DATABLAD MODULEX 250A

VARENØ. 70260 MÅLEMODUL EBM 160A

Prod.nr.	Innhold	Ant.
4383604	Effektbryter 4P T4N 250 -LS/I In=160	1
75144	Overspenningsvern OVR T2 3L 40400 PX	1
75145	Sikringsholder	1
72960	Målertrafo KS60-0200/5 KL 0,2s	3
4383666	Kabelklemme FC CuAl T4 2x35-150 mm ²	4
75146	Glassikring 10A for overspenningsvern	3
75144	Faseskiller PB100 T4-T5 4p lav	4
1SCA022512R5360	Pluggkontakt 125/160A	1



Effektbryter 4P T4N 250 -LS/I In=160

Elnummer: 4383604
Fabrikat: ABB SACE

[FDV](#)



**Kabelklemme FC CuAl T4
2x35-150 mm²**

Elnummer: 4383666
Tiltrekningskraft: 16Nm

[FDV](#)



Overspenningsvern OVR T2 3L 40400 PX

Elnummer: 1623898
Fabrikat: ABB



**Glassikring 10A for over-
spenningsvern**

Elnummer: 1655016
Fabrikat: ABB

[FDV](#)



Sikringsholder

Elnummer: 1425442
Fabrikat: ABB

[FDV](#)



Faseskiller PB100 T4-T5 4p lav

Elnummer: 4383656
Fabrikat: ABB Sace

[FDV](#)



Målertrafo KS60-0200/5 KL 0,2s

Fabrikat: Hugo Tilquist AB



Pluggkontakt 125/160A

Elnummer: 1SCA022512R5360
PG400S4

ATABLAD MODULEX 250A VAREN. 70260 MÅLEMODUL EBM 160A

Enlinjeskjema

